

County of Brunswick

3954 Clearwell Dr NE
Leland, NC 28451

Northwest Water Plant

Leland, NC
Samples Received: 08/11/22

Analytical Report 0822-745

Isotope Dilution Method PFAS



Enthalpy Analytical, LLC – Ultratrace

Mark Hager

O: 910-876-6894/ F: 910-212-6886

mark.hager@enthalpy.com / www.enthalpy.com

2714 Exchange Drive, Wilmington, NC 28405

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains _____ pages.

Report Issued Date: _____



Summary of Results

Enthalpy Analytical

Job No.: 0822-745-1 PFAS by Isotope Dilution (non-potable water)

Brunswick County Public Utilities - NC Client Project: N/A Site: Northwest Water Plant

Summary

	Compound	CAS	081122S01 ng/L	081122E01 ng/L
Acids	PFBA	375-22-4	8.07	6.03
	PFPeA	2706-90-3	17.3	16.3
	PFHxA	307-24-4	10.3	10.9
	PFHpA	375-85-9	4.58	4.14
	PFOA	335-67-1	6.70	6.29
	PFNA	375-95-1	1.12	0.996
	PFDA	335-76-2	0.739	0.692
	PFUnDA	2058-94-8	0.217 J	0.214 J
	PFDoDA	307-55-1	0.0266 L	0.0109 L
	PFTTrDA	72629-94-8	0.0153 L	ND U
Sulfonates	PFTeDA	376-06-7	ND U	0.00179 L
	PFBS	375-73-5	6.32	6.75
	PFPeS	2706-91-4	0.985	1.10
	PFHxS	355-46-4	5.60	5.07
	PFHpS	375-92-8	0.230 J	0.232 J
	PFOS	1763-23-1	12.4	11.5
	PFNS	68259-12-1	ND U	ND U
	PFDS	335-77-3	ND U	ND U
	4:2 FTS	757124-72-4	ND U	ND U
	6:2 FTS	27619-97-2	0.409 J	1.14
Other	8:2 FTS	39108-34-4	ND U	ND U
	PFOSA	754-91-6	0.0269 LB	0.0491 L
	N-MeFOSAA	2355-31-9	ND U	0.0633 L
	N-EtFOSAA	2991-50-6	0.0212 L	ND U
	HFPO-DA	13252-13-6	10.4	10.7
	PFMOAA	674-13-5	85.2	85.6
	PFMOPrA	377-73-1	ND U	0.152 L
	PFO2HxA	39492-88-1	11.1	10.7
	PFO3OA	39492-89-2	2.83	1.36
	PFO4DA	39492-90-5	ND U	ND U
	Nafion Byproduct 1	29311-67-9	ND U	ND U
	ADONA	919005-14-4	ND U	ND U
	9Cl-PF3ONS	756426-58-1	ND U	ND U
	11Cl-PF3OUdS	763051-92-9	ND U	ND U
	10:2 FTS	120226-60-0	ND U	ND U
	EVE Acid	69087-46-3	ND U	ND U
	FBSA	30334-69-1	1.60	1.34
	Hydro-EVE Acid	773804-62-9	0.522 L	0.499 L
	Hydrolyzed PSDA	2416366-19-1	17.3	26.3
	Nafion Byproduct 2	749836-20-2	0.456 J	0.409 J
	N-EtFOSA	4151-50-2	ND U	ND U
	N-EtFOSE	1691-99-2	ND U	ND U
	NFDHA	151772-58-6	ND U	ND U
	N-MeFOSA	31506-32-8	ND U	ND U
	N-MeFOSE	24448-09-7	ND U	ND U
	NVHOS	1132933-86-8	5.63	5.40
	PEPA	267239-61-2	5.36	5.25
	PFECA-G	801212-59-9	ND U	ND U
	PFEESA	113507-82-7	ND U	ND U
	PFHxDA	67905-19-5	ND U	ND U
	PFMOBA	863090-89-5	ND U	ND U
	PFO5DA	39492-91-6	ND U	ND U
	PMPA	13140-29-9	13.3	12.7
	R-EVE	2416366-22-6	11.5	9.85
	R-PSDA	2416366-18-0	ND U	ND U
	R-PSDCA	241636-21-5	0.155 L	0.139 L

Detailed Results

Enthalpy Analytical

Job No.: 0822-745-1 PFAS by Isotope Dilution (non-potable water)

Brunswick County Public Utilities - NC Client Project: N/A Site: Northwest Water Plant

Enthalpy ID	0822-745-001-1	Prep Batch	EU13837	Sample Vol (mL)	283.02
Sample Name	081122S01	Prep Date	2022-08-12 09:40	Extract Vol (mL)	0.4
Matrix	Aqueous	Analysis Date	2022-08-28 06:03	Split Factor	N/A
Sampling Date	20220811 00:00	Analyst	rappelle	Method Code	WM-026
Received Date	2022-08-11 14:15	Instrument	Sauron	Sample Type	Sample

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery Limits	Recovery	Flags
Acids	PFBA	375-22-4	5710.54	8.07	8.07	0.135	0.565			
	PFPeA	2706-90-3	12235.16	17.3	17.3	0.150	0.565			
	PFHxA	307-24-4	7285.93	10.3	10.3	0.170	0.565			
	PFHpA	375-85-9	3239.30	4.58	4.58	0.108	0.565			
	PFOA	335-67-1	4737.25	6.70	6.70	0.156	0.565			
	PFNA	375-95-1	789.09	1.12	1.12	0.0672	0.565			
	PFDA	335-76-2	522.74	0.739	0.739	0.0746	0.565			
	PFUnDA	2058-94-8	153.83	0.217	0.217	0.163	0.565			J
	PFDoDA	307-55-1	18.79	0.0266	0.0266	0.178	0.565			L
	PFTriDA	72629-94-8	10.82	0.0153	0.0153	0.133	0.565			L
Sulfonates	PFTeDA	376-06-7	ND	ND	ND	0.193	0.565			U
	PFBS	375-73-5	4469.50	6.32	6.32	0.314	0.660			
	PFPeS	2706-91-4	697.27	0.985	0.985	0.182	0.533			
	PFHxS	355-46-4	3964.49	5.60	5.60	0.169	0.518			
	PFHpS	375-92-8	162.72	0.230	0.230	0.119	0.539			J
	PFOS	1763-23-1	8789.27	12.4	12.4	0.141	0.524			
	PFNS	68259-12-1	ND	ND	ND	0.0763	0.545			U
	PFDS	335-77-3	ND	ND	ND	0.170	0.545			U
	4:2 FTS	757124-72-4	ND	ND	ND	0.104	0.530			U
	6:2 FTS	27619-97-2	289.36	0.409	0.409	0.102	0.539			J
Other	8:2 FTS	39108-34-4	ND	ND	ND	0.151	0.542			U
	PFOSA	754-91-6	19.06	0.0269	0.0269	0.115	0.565			LB
	N-MeFOSAA	2355-31-9	ND	ND	ND	0.127	0.565			U
	N-EtFOSAA	2991-50-6	15.00	0.0212	0.0212	0.0963	0.565			L
	HFPO-DA	13252-13-6	7339.68	10.4	10.4	0.201	0.565			
	PFMOAA	674-13-5	60303.86	85.2	85.2	1.27	1.27			
	PFMOPrA	377-73-1	ND	ND	ND	0.212	0.565			U
	PFO2HxA	39492-88-1	7872.43	11.1	11.1	1.27	1.27			
	PFO3OA	39492-89-2	2000.08	2.83	2.83	1.27	1.27			
	PFO4DA	39492-90-5	ND	ND	ND	1.34	1.34			U
	Nafion Byproduct 1	29311-67-9	ND	ND	ND	0.269	0.565			U
	ADONA	919005-14-4	ND	ND	ND	0.106	0.536			U
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.106	0.527			U
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.106	0.533			U
	10:2 FTS	120226-60-0	ND	ND	ND	0.212	0.565			U
	EVE Acid	69087-46-3	ND	ND	ND	1.27	1.27			U
	FBSA	30334-69-1	1133.76	1.60	1.60	0.212	0.565			
	Hydro-EVE Acid	773804-62-9	369.58	0.522	0.522	1.27	1.27			L
	Hydrolyzed PSDA	2416366-19-1	12250.74	17.3	17.3	1.27	1.27			
	Nafion Byproduct 2	749836-20-2	322.35	0.456	0.456	0.269	0.565			J
	N-EtFOSA	4151-50-2	ND	ND	ND	0.212	0.565			U
	N-EtFOSE	1691-99-2	ND	ND	ND	6.36	6.36			U
	NFDHA	151772-58-6	ND	ND	ND	0.212	0.565			U
	N-MeFOSA	31506-32-8	ND	ND	ND	0.212	0.565			U
	N-MeFOSE	24448-09-7	ND	ND	ND	6.36	6.36			U
	NVHOS	1132933-86-8	3982.92	5.63	5.63	1.27	1.27			
	PEPA	267239-61-2	3791.08	5.36	5.36	1.27	1.27			
	PFECA-G	801212-59-9	ND	ND	ND	0.269	1.27			U
	PFEESA	113507-82-7	ND	ND	ND	0.212	0.565			U
	PFHxDA	67905-19-5	ND	ND	ND	1.27	1.27			U
	PFMOBA	863090-89-5	ND	ND	ND	1.27	1.27			LB
	PFO5DA	39492-91-6	ND	ND	ND	1.34	1.34			U
	PMPA	13140-29-9	9409.40	13.3	13.3	1.27	1.27			L
	R-EVE	2416366-22-6	8136.46	11.5	11.5	1.27	1.27			
	R-PSDA	2416366-18-0	ND	ND	ND	1.27	1.27			
	R-PSDCA	241636-21-5	109.62	0.155	0.155	1.27	1.27			U
ES	MPFBA		4348.75	6.15				20-150%	87.0%	
	M5PFPeA		7666.92	10.8				20-150%	153.3%	Q
	M3PFBS		10481.18	14.8				20-150%	209.6%	Q
	M2-4:2 FTS		11010.09	15.6				20-150%	220.2%	Q
	M5PFHxA		4050.67	5.72				20-150%	81.0%	
	M3HFPO-DA		3314.33	4.68				20-150%	66.3%	
	M4PFHpA		4375.98	6.18				20-150%	87.5%	
	M3PFHxS		5074.73	7.17				20-150%	101.5%	
	M2-6:2 FTS		4613.69	6.52				20-150%	92.3%	
	M8PFOA		4158.44	5.88				20-150%	83.2%	
	M9PFNA		4089.92	5.78				20-150%	81.8%	
	M8PFOS		4293.98	6.07				20-150%	85.9%	
	M2-8:2 FTS		4759.63	6.73				20-150%	95.2%	
	M8FOSA-I		3186.84	4.50				20-150%	63.7%	
	M6PFDA		4516.19	6.38				20-150%	90.3%	
	d3-N-MeFOSAA		3188.47	4.51				20-150%	63.8%	
	d5-N-EtFOSAA		3100.79	4.38				20-150%	62.0%	
	M7PFUdA		3205.87	4.53				20-150%	64.1%	
	MPFDaA		2686.30	3.80				20-150%	53.7%	
	M2PFTeDA		1189.08	1.68				20-150%	23.8%	
	d3-N-MeFOSA		1404.46	1.98				10-200%	14.0%	
	d5-N-EtFOSA		1049.33	1.48				10-200%	10.5%	
	d7-N-MeFOSE		3174.13	4.49				10-200%	31.7%	
	d9-N-EtFOSE		2565.48	3.63				10-200%	25.7%	
	M2PFHxDA		942.76	1.33				10-200%	18.9%	

Enthalpy Analytical

Job No.: 0822-745-1 PFAS by Isotope Dilution (non-potable water)

Brunswick County Public Utilities - NC Client Project: N/A Site: Northwest Water Plant

Enthalpy ID	0822-745-002-1	Prep Batch	EU13837	Sample Vol (mL)	288.47
Sample Name	081122E01	Prep Date	2022-08-12 09:40	Extract Vol (mL)	0.4
Matrix	Aqueous	Analysis Date	2022-08-28 06:26	Split Factor	N/A
Sampling Date	20220811 00:00	Analyst	rappelle	Method Code	WM-026
Received Date	2022-08-11 14:15	Instrument	Sauron	Sample Type	Sample

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery Limits	Recovery	Flags
Acids	PFBA	375-22-4	4351.15	6.03	6.03	0.133	0.555			
	PFPeA	2706-90-3	11784.02	16.3	16.3	0.147	0.555			
	PFHxA	307-24-4	7866.62	10.9	10.9	0.167	0.555			
	PFHpA	375-85-9	2987.30	4.14	4.14	0.106	0.555			
	PFOA	335-67-1	4539.56	6.29	6.29	0.153	0.555			
	PFNA	375-95-1	718.10	0.996	0.996	0.0659	0.555			
	PFDA	335-76-2	498.77	0.692	0.692	0.0732	0.555			
	PFUnDA	2058-94-8	154.10	0.214	0.214	0.160	0.555			J
	PFDoDA	307-55-1	7.87	0.0109	0.0109	0.175	0.555			L
	PFTriDA	72629-94-8	ND	ND	ND	0.131	0.555			U
Sulfonates	PFTeDA	376-06-7	1.29	0.00179	0.00179	0.189	0.555			L
	PFBS	375-73-5	4866.67	6.75	6.75	0.308	0.648			
	PFPeS	2706-91-4	793.72	1.10	1.10	0.179	0.523			
	PFHxS	355-46-4	3653.45	5.07	5.07	0.166	0.508			
	PFHpS	375-92-8	167.50	0.232	0.232	0.117	0.528			J
	PFOS	1763-23-1	8261.75	11.5	11.5	0.139	0.514			
	PFNS	68259-12-1	ND	ND	ND	0.0749	0.534			U
	PFDS	335-77-3	ND	ND	ND	0.166	0.534			U
	4:2 FTS	757124-72-4	ND	ND	ND	0.102	0.520			U
	6:2 FTS	27619-97-2	820.98	1.14	1.14	0.101	0.528			
Other	8:2 FTS	39108-34-4	ND	ND	ND	0.148	0.531			U
	PFOSA	754-91-6	35.43	0.0491	0.0491	0.113	0.555			L
	N-MeFOSAA	2355-31-9	45.65	0.0633	0.0633	0.125	0.555			L
	N-EtFOSAA	2991-50-6	ND	ND	ND	0.0945	0.555			U
	HFPO-DA	13252-13-6	7694.42	10.7	10.7	0.198	0.555			
	PFMOAA	674-13-5	61734.92	85.6	85.6	1.25	1.25			
	PFMOPrA	377-73-1	109.59	0.152	0.152	0.208	0.555			L
	PFO2HxA	39492-88-1	7732.49	10.7	10.7	1.25	1.25			
	PFO3OA	39492-89-2	983.73	1.36	1.36	1.25	1.25			
	PFO4DA	39492-90-5	ND	ND	ND	1.32	1.32			U
	Nafion Byproduct 1	29311-67-9	ND	ND	ND	0.263	0.555			U
	ADONA	919005-14-4	ND	ND	ND	0.104	0.525			U
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.104	0.517			U
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.104	0.523			U
	10:2 FTS	120226-60-0	ND	ND	ND	0.208	0.555			U
	EVE Acid	69087-46-3	ND	ND	ND	1.25	1.25			U
	FBSA	30334-69-1	965.63	1.34	1.34	0.208	0.555			
	Hydro-EVE Acid	773804-62-9	359.94	0.499	0.499	1.25	1.25			L
	Hydrolyzed PSDA	2416366-19-1	18995.81	26.3	26.3	1.25	1.25			
	Nafion Byproduct 2	749836-20-2	295.00	0.409	0.409	0.263	0.555			J
	N-EtFOSA	4151-50-2	ND	ND	ND	0.208	0.555			U
	N-EtFOSE	1691-99-2	ND	ND	ND	6.24	6.24			U
	NFDHA	151772-58-6	ND	ND	ND	0.208	0.555			U
	N-MeFOSA	31506-32-8	ND	ND	ND	0.208	0.555			U
	N-MeFOSE	24448-09-7	ND	ND	ND	6.24	6.24			U
	NVHOS	1132933-86-8	3895.93	5.40	5.40	1.25	1.25			
	PEPA	267239-61-2	3784.18	5.25	5.25	1.25	1.25			
	PFECA-G	801212-59-9	ND	ND	ND	0.263	1.25			U
	PFEESA	113507-82-7	ND	ND	ND	0.208	0.555			U
	PFHxDA	67905-19-5	ND	ND	ND	1.25	1.25			U
	PFMOBA	863090-89-5	ND	ND	ND	1.25	1.25			L
	PFO5DA	39492-91-6	ND	ND	ND	1.32	1.32			L
	PMPA	13140-29-9	9165.69	12.7	12.7	1.25	1.25			U
	R-EVE	2416366-22-6	7100.19	9.85	9.85	1.25	1.25			
	R-PSDA	2416366-18-0	ND	ND	ND	1.25	1.25			
	R-PSDCA	241636-21-5	100.20	0.139	0.139	1.25	1.25			L
ES	MPFBA		4263.15	5.91				20-150%	85.3%	
	M5PFPeA		6661.04	9.24				20-150%	133.2%	
	M3PFBS		9709.07	13.5				20-150%	194.2%	Q
	M2-4:2 FTS		15108.34	20.9				20-150%	302.2%	Q
	M5PFHxA		3292.25	4.57				20-150%	65.8%	
	M3HFPO-DA		2862.85	3.97				20-150%	57.3%	
	M4PFHpA		4202.02	5.83				20-150%	84.0%	
	M3PFHxS		4994.50	6.93				20-150%	99.9%	
	M2-6:2 FTS		9528.96	13.2				20-150%	190.6%	Q
	M8PFOA		4615.44	6.40				20-150%	92.3%	
	M9PFNA		4112.05	5.70				20-150%	82.2%	
	M8PFOS		4270.81	5.92				20-150%	85.4%	
	M2-8:2 FTS		5897.43	8.18				20-150%	117.9%	
	M8FOSA-I		3369.29	4.67				20-150%	67.4%	
	M6PFDA		4429.86	6.14				20-150%	88.6%	
	d3-N-MeFOSAA		3637.05	5.04				20-150%	72.7%	
	d5-N-EtFOSAA		3503.67	4.86				20-150%	70.1%	
	M7PFUdA		3646.68	5.06				20-150%	72.9%	
	MPFDa		3293.90	4.57				20-150%	65.9%	
	M2PFTeDA		2357.04	3.27				20-150%	47.1%	
	d3-N-MeFOSA		2905.28	4.03				10-200%	29.1%	
	d5-N-EtFOSA		2457.79	3.41				10-200%	24.6%	
	d7-N-MeFOSE		5802.89	8.05				10-200%	58.0%	
	d9-N-EtFOSE		5593.86	7.76				10-200%	55.9%	
	M2PFHxDA		1990.59	2.76				10-200%	39.8%	

QC Data

Enthalpy Analytical

Job No.: 0822-745-1 PFAS by Isotope Dilution (non-potable water)

Brunswick County Public Utilities - NC Client Project: N/A Site: Northwest Water Plant

Enthalpy ID	MB-13837-PFAS	Prep Batch	EU13837	Sample Vol (mL)	250
Sample Name	MB-13837-PFAS	Prep Date	2022-08-12 09:40	Extract Vol (mL)	0.4
Matrix	aqueous	Analysis Date	2022-08-28 04:54	Split Factor	N/A
Sampling Date		Analyst	rapelle	Method Code	WM-026
Received Date		Instrument	Sauron	Sample Type	Blank

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery Limits	Recovery	Flags
Acids	PFBA	375-22-4	ND	ND	ND	0.153	0.640			U
	PFPeA	2706-90-3	ND	ND	ND	0.170	0.640			U
	PFHxA	307-24-4	ND	ND	ND	0.193	0.640			U
	PFHpA	375-85-9	ND	ND	ND	0.122	0.640			U
	PFOA	335-67-1	ND	ND	ND	0.177	0.640			U
	PFNA	375-95-1	ND	ND	ND	0.0761	0.640			U
	PFDA	335-76-2	8.80	0.0141	0.0141	0.0845	0.640			L
	PFUnDA	2058-94-8	ND	ND	ND	0.185	0.640			U
	PFDoDA	307-55-1	ND	ND	ND	0.202	0.640			U
	PFTTrDA	72629-94-8	ND	ND	ND	0.151	0.640			U
Sulfonates	PFTeDA	376-06-7	ND	ND	ND	0.218	0.640			U
	PFBS	375-73-5	ND	ND	ND	0.355	0.747			U
	PFPeS	2706-91-4	ND	ND	ND	0.206	0.603			U
	PFHxS	355-46-4	ND	ND	ND	0.191	0.586			U
	PFHpS	375-92-8	ND	ND	ND	0.135	0.610			U
	PFOS	1763-23-1	ND	ND	ND	0.160	0.593			U
	PFNS	68259-12-1	ND	ND	ND	0.0864	0.616			U
	PFDS	335-77-3	ND	ND	ND	0.192	0.616			U
	4:2 FTS	757124-72-4	ND	ND	ND	0.118	0.600			U
	6:2 FTS	27619-97-2	ND	ND	ND	0.116	0.610			U
Other	8:2 FTS	39108-34-4	ND	ND	ND	0.171	0.613			U
	PFOSA	754-91-6	3.01	0.00482	0.00482	0.130	0.640			L
	N-MeFOSAA	2355-31-9	ND	ND	ND	0.144	0.640			U
	N-EtFOSAA	2991-50-6	ND	ND	ND	0.109	0.640			U
	HFPO-DA	13252-13-6	ND	ND	ND	0.228	0.640			U
	PFMOAA	674-13-5	ND	ND	ND	1.44	1.44			U
	PFMOPrA	377-73-1	ND	ND	ND	0.240	0.640			U
	PFO2HxA	39492-88-1	ND	ND	ND	1.44	1.44			U
	PFO3OA	39492-89-2	ND	ND	ND	1.44	1.44			U
	PFO4DA	39492-90-5	ND	ND	ND	1.52	1.52			U
	Nafion Byproduct 1	29311-67-9	ND	ND	ND	0.304	0.640			U
	ADONA	919005-14-4	ND	ND	ND	0.120	0.606			U
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.120	0.596			U
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.120	0.603			U
	10:2 FTS	120226-60-0	ND	ND	ND	0.240	0.640			U
	EVE Acid	69087-46-3	ND	ND	ND	1.44	1.44			U
	FBSA	30334-69-1	ND	ND	ND	0.240	0.640			U
	Hydro-EVE Acid	773804-62-9	ND	ND	ND	1.44	1.44			U
	Hydrolyzed PSDA	2416366-19-1	ND	ND	ND	1.44	1.44			U
	Nafion Byproduct 2	749836-20-2	ND	ND	ND	0.304	0.640			U
	N-EtFOSA	4151-50-2	ND	ND	ND	0.240	0.640			U
	N-EtFOSE	1691-99-2	58.95	0.0943	0.0943	7.20	7.20			L
	NFDHA	151772-58-6	ND	ND	ND	0.240	0.640			U
	N-MeFOSA	31506-32-8	ND	ND	ND	0.240	0.640			U
	N-MeFOSE	24448-09-7	69.20	0.111	0.111	7.20	7.20			L
	NVHOS	1132933-86-8	ND	ND	ND	1.44	1.44			U
	PEPA	267239-61-2	ND	ND	ND	1.44	1.44			U
	PFECA-G	801212-59-9	ND	ND	ND	0.304	1.44			U
	PFEESA	113507-82-7	ND	ND	ND	0.240	0.640			U
	PFHxDA	67905-19-5	ND	ND	ND	1.44	1.44			U
	PFMOBA	863090-89-5	ND	ND	ND	1.44	1.44			U
	PFO5DA	39492-91-6	ND	ND	ND	1.52	1.52			U
	PMPA	13140-29-9	ND	ND	ND	1.44	1.44			U
	R-EVE	2416366-22-6	ND	ND	ND	1.44	1.44			U
	R-PSDA	2416366-18-0	ND	ND	ND	1.44	1.44			U
	R-PSDCA	241636-21-5	ND	ND	ND	1.44	1.44			U
ES	MPFBA		4405.68	7.05				20-150%	88.1%	
	M5PFPeA		4227.68	6.76				20-150%	84.6%	
	M3PFBS		3948.13	6.32				20-150%	79.0%	
	M2-4:2 FTS		4215.81	6.75				20-150%	84.3%	
	M5PFHxA		4084.63	6.54				20-150%	81.7%	
	M3HFPO-DA		3620.58	5.79				20-150%	72.4%	
	M4PFHpA		4395.10	7.03				20-150%	87.9%	
	M3PFHxS		4220.28	6.75				20-150%	84.4%	
	M2-6:2 FTS		3724.43	5.96				20-150%	74.5%	
	M8PFOA		4387.31	7.04				20-150%	87.9%	
	M9PFNA		4085.10	6.54				20-150%	81.7%	
	M8PFOS		4023.17	6.44				20-150%	80.5%	
	M2-8:2 FTS		4016.57	6.43				20-150%	80.3%	
	M8FOSA-I		3525.24	5.64				20-150%	70.5%	
	M6PFDA		4209.35	6.73				20-150%	84.2%	
	d3-N-MeFOSAA		3271.91	5.24				20-150%	65.4%	
	d5-N-EtFOSAA		3198.58	5.12				20-150%	64.0%	
	M7PFUdA		3561.92	5.70				20-150%	71.2%	
	MPFDaA		3535.40	5.66				20-150%	70.7%	
	M2PFTeDA		2905.08	4.65				20-150%	58.1%	
	d3-N-MeFOSA		5208.75	8.33				10-200%	52.1%	
	d5-N-EtFOSA		5471.05	8.75				10-200%	54.7%	
	d7-N-MeFOSE		8110.44	13.0				10-200%	81.1%	
	d9-N-EtFOSE		8732.77	14.0				10-200%	87.3%	
	M2PFHxDA		264.49	0.423				10-200%	5.3%	Q

Enthalpy Analytical

Job No.: 0822-745-1 PFAS by Isotope Dilution (non-potable water)

Brunswick County Public Utilities - NC Client Project: N/A Site: Northwest Water Plant

Enthalpy ID	OPR-13837-PFAS	Prep Batch	EU13837	Sample Vol (mL)	250
Sample Name	OPR-13837-PFAS	Prep Date	2022-08-12 09:40	Extract Vol (mL)	0.4
Matrix	aqueous	Analysis Date	2022-08-28 05:17	Split Factor	N/A
Sampling Date		Analyst	rappelle	Method Code	WM-026
Received Date		Instrument	Sauron	Sample Type	Control

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery Limits	Recovery	Flags
Acids	PFBA	375-22-4	12810.47	20.5	20.5	0.153	0.640	73-129%	102.5%	
	PFPeA	2706-90-3	12782.13	20.5	20.5	0.170	0.640	72-129%	102.3%	
	PFHxA	307-24-4	11720.83	18.8	18.8	0.193	0.640	72-129%	93.8%	
	PFHpA	375-85-9	11957.91	19.1	19.1	0.122	0.640	72-130%	95.7%	
	PFOA	335-67-1	12439.89	19.9	19.9	0.177	0.640	71-133%	99.5%	
	PFNA	375-95-1	11704.22	18.7	18.7	0.0761	0.640	69-130%	93.6%	
	PFDA	335-76-2	12018.35	19.2	19.2	0.0845	0.640	71-129%	96.1%	
	PFUnDA	2058-94-8	11277.74	18.0	18.0	0.185	0.640	69-133%	90.2%	
	PFDoDA	307-55-1	10897.56	17.4	17.4	0.202	0.640	72-134%	87.2%	
	PFTTrDA	72629-94-8	13727.16	22.0	22.0	0.151	0.640	65-144%	109.8%	
Sulfonates	PFTeDA	376-06-7	10813.40	17.3	17.3	0.218	0.640	71-132%	86.5%	
	PFBS	375-73-5	9361.48	15.0	15.0	0.355	0.747	72-134%	84.4%	
	PFPeS	2706-91-4	10477.52	16.8	16.8	0.206	0.603	71-127%	89.1%	
	PFHxS	355-46-4	9220.52	14.8	14.8	0.191	0.586	68-131%	80.7%	
	PFHpS	375-92-8	10822.10	17.3	17.3	0.135	0.610	69-134%	90.8%	
	PFOS	1763-23-1	10735.48	17.2	17.2	0.160	0.593	65-140%	92.5%	
	PFNS	68259-12-1	10743.41	17.2	17.2	0.0864	0.616	69-127%	89.3%	
	PFDS	335-77-3	10200.13	16.3	16.3	0.192	0.616	53-142%	84.6%	
	4:2 FTS	757124-72-4	12407.94	19.9	19.9	0.118	0.600	63-143%	105.9%	
	6:2 FTS	27619-97-2	12604.41	20.2	20.2	0.116	0.610	64-140%	106.0%	
Other	8:2 FTS	39108-34-4	12106.79	19.4	19.4	0.171	0.613	67-138%	100.9%	
	PFOSA	754-91-6	12444.85	19.9	19.9	0.130	0.640	67-137%	99.6%	
	N-MeFOSAA	2355-31-9	11985.19	19.2	19.2	0.144	0.640	65-136%	95.9%	
	N-EtFOSAA	2991-50-6	12269.80	19.6	19.6	0.109	0.640	61-135%	98.2%	
	HFPO-DA	13252-13-6	12487.85	20.0	20.0	0.228	0.640	70-130%	99.9%	
ES	MPFBA		4270.50	6.83				20-150%	85.4%	
	M5PFPeA		4402.67	7.04				20-150%	88.1%	
	M3PFBS		4317.26	6.91				20-150%	86.3%	
	M2-4:2 FTS		3775.15	6.04				20-150%	75.5%	
	M5PFHxA		4003.64	6.41				20-150%	80.1%	
	M3HFPO-DA		3388.26	5.42				20-150%	67.8%	
	M4PFHpA		4205.69	6.73				20-150%	84.1%	
	M3PFHxS		4920.05	7.87				20-150%	98.4%	
	M2-6:2 FTS		3649.02	5.84				20-150%	73.0%	
	M8PFOA		4158.51	6.65				20-150%	83.2%	
	M9PFNA		4421.07	7.07				20-150%	88.4%	
	M8PFOS		3904.36	6.25				20-150%	78.1%	
	M2-8:2 FTS		4357.31	6.97				20-150%	87.1%	
	M8FOSA-I		2609.21	4.17				20-150%	52.2%	
	M6PFDA		4412.78	7.06				20-150%	88.3%	
	d3-N-MeFOSAA		3196.43	5.11				20-150%	63.9%	
	d5-N-EtFOSAA		3125.50	5.00				20-150%	62.5%	
	M7PFUDa		3763.75	6.02				20-150%	75.3%	
	MPFDoA		3615.07	5.78				20-150%	72.3%	
	M2PFTeDA		2854.97	4.57				20-150%	57.1%	
	d3-N-MeFOSA		1652.75	2.64				10-200%	16.5%	
	d5-N-EtFOSA		1693.58	2.71				10-200%	16.9%	
	d7-N-MeFOSE		5978.99	9.57				10-200%	59.8%	
	d9-N-EtFOSE		6137.31	9.82				10-200%	61.4%	
	M2PFHxDA		374.95	0.600				10-200%	7.5%	Q

Narrative Summary

Enthalpy Analytical Narrative Summary

Company	Brunswick County Public Utilities - NC
Job No.	0822-745-1 PFAS by Isotope Dilution (non-potable water)
Client ID.	N/A Site: Northwest Water Plant

1. Custody

Megan Holden received the samples on August 11, 2022 at 17.3 °C after being relinquished by Brunswick County Public Utilities - NC. The samples were received in good condition.

Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, LLC.

Table 1 - Sample Inventory

EU Lab Sample ID	Client Sample ID	Matrix
0822-745-001-1	081122S01	Aqueous
0822-745-002-1	081122E01	Aqueous

2. Methods and Analytes

A list of analytes of interest and corresponding methods of analysis is shown in Table 3. Abbreviations are defined in the listed Appendices.

Table 3 - Methods and Analytes

EU Method	Analytes	Cleanup Method
EU-047	Brunswick PFAS List	ENVI-Carb

3. Analysis

The samples were analyzed using Waters Acquity UPLC equipped with Xevo TQ MS (LC/MS/MS "Sauron").

For aqueous samples, the sample volume was measured gravimetrically by the laboratory, and spiked with Extraction Standard (ES). The sample was then mixed well and centrifuged, if needed. The samples were then extracted via SPE, and the extracts were cleaned up using ENVI-Carb.

Each final sample extract was transferred to an autosampler vial, spiked with Injection Standard (IS), and brought to a final volume of 400µL prior to analysis.

4. Calibration

In the initial calibration, the reported analytes exhibited R^2 of ≥ 0.99 .

Except where noted below, the reported analytes in the calibration standards, continuing calibration (concal) and Initial Calibration Verification (ICV) met the 30% accuracy criterion for native analytes.

PFAS R-PSDA fell above method control limits in the opening concal. This analyte was not detected in the samples; therefore, the data is reported without adverse impact.

Enthalpy Analytical Narrative Summary

Company	Brunswick County Public Utilities - NC
Job No.	0822-745-1 PFAS by Isotope Dilution (non-potable water)
Client ID.	N/A Site: Northwest Water Plant

4. Calibration, continued

The Technical Director extended the method criteria for certain non-legacy analytes that do not have their own internal standard and exhibit observed variability during calibration.

5. QC Notes

The QC sample analyses passed all method criteria.

The samples were extracted within the 28-day from collection holding time and analyzed within the 28-day from extraction to analysis holding time required by the method.

Samples received above 6 °C, client notified in order acknowledgement documentation.

6. Reporting Notes

This report provides all results including detections below LOD following client instruction.

Analyte(s) were detected in the method blank (MB) at less than 1/2 LOQ that may also be less than LOD. Any of these analyte(s) detected in the samples with less than 10 times the amount detected in MB were notated with a B qualifier and are reported with no adverse impact.

Some labeled extraction standards in the sample analyses fell outside the control limits for ES recovery, as denoted by the "Q" qualifier. The target analytes are quantified based on their ratio to their labeled standard analogs. As a result, low or high labeled standard recovery do not cause any change to ratios or contribute any additional error in the measurement of the target analytes. The data have been accepted and reported with no further actions.

The results presented in this report are representative of the samples as provided to the laboratory.

These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.

Enthalpy Analytical, LLC in Wilmington NC is accredited by the Louisiana Department of Environmental Quality to the 2009 TNI Standard under certificate number 05075.

General Reporting Notes – Data Qualifiers

The following are general reporting notes that are applicable to all Enthalpy Analytical, LLC - Wilmington, NC data reports, unless specifically noted otherwise.

General Data Qualifiers

- B – The analyte was found in the method blank, at a concentration that was at least 10% of the amount in the sample.
- Cxx – Two or more congeners co-elute. In EDDs, C denotes the lowest IUPAC congener in a co-elution group and additional co-eluters for the group ('xx') are shown with the number of the lowest IUPAC co-eluter.
- E – The reported concentration exceeds the calibration range (upper point of the calibration curve). For HRMS data, this condition does not imply additional measurement uncertainty. For LC-MS/MS data, these values should be considered as having measurement uncertainty higher than values within the calibration range.
- EDL – Estimated Detection Level: The EDL is unique to isotope dilution methods and reflects the conditions of analysis at the time of analysis, including the equipment used. Where the MDL is a static value, the EDL is a dynamic value.
- EMPC – Estimated Maximum Possible Concentration: EMPC is specific to Dioxin/Furan tests to indicate the determined ion-abundance ratio was outside the allowed theoretical range (usually due to being near the detection limit, although it can very rarely be caused by a co-eluting interference). The EMPC concentration is adjusted to reflect the value at the theoretical ion-abundance ratio.
- IR – The ion ratio between the primary and secondary ions was observed to be outside the method criteria. The analyte concentration may be inaccurate due to interference.
- J – The analyte has a concentration below the minimum calibration level (LOQ value) but greater than the LOD. These values should be considered as having measurement uncertainty higher than values within the calibration range
- L - Indicates that an analyte has a concentration below the Minimum Detection Limit (MDL). The reported concentration is not recommended for regulatory use as the analyte signal may have a signal-to-noise ratio less than the criteria deemed necessary to be considered a detected analyte.
- LOD – Limit of Detection: For reports conforming to the DOD ELAP QSM, this is the QSM-defined LOD. For reports conforming to TNI requirements (but not DOD ELAP QSM requirements), this value is the minimum detection limit (MDL). The LOD is adjusted for sample weight or volume.
- LOQ – Limit of Quantitation: For reports conforming to the DOD ELAP QSM, this is the QSM-defined LOQ. For reports conforming to TNI requirements (but not DOD ELAP QSM requirements), this value is the reporting limit (RL). The LOQ is adjusted for sample weight or volume.

General Reporting Notes – Data Qualifiers

- <LOD() – Analyte was not found at a concentration high enough to be reported as detected. It is reported as less than the LOD, and the LOD is given in the parentheses.
- <LOQ() – Analyte was not found at a concentration high enough to be reported as above the QSM-defined LOQ or TNI defined Reporting Limit. It is reported as less than the LOQ, and the LOQ is given in the parentheses.
- ND – Indicates a non-detect.
- NR – Indicates a value that is not reportable due to issues observed in sample preparation or analysis.
- PR – The associated congener(s) is(are) poorly resolved.
- QI – Indicates the presence of a quantitative interference.
- RL – Reporting Limit. Lowest reportable value. The level is higher than the MDL.
- SI – Denotes “Single Ion Mode” and is utilized for PCBs where the secondary ion trace has a significantly elevated noise level due to background PFK. Responses for such peaks are calculated using an EMPC approach based solely on the primary ion area(s) and may be considered estimates.
- U – The analyte was not detected.
- V / Q – The labeled standard recovery is not within method control limits.
- X – Indicates the result is from re-injection/repeat/second-column analysis.

Lab Identifiers/ Data Attributes

- AR – Indicates use of the archived portion of the sample extract.
- CU – Indicates a sample that required additional clean-up prior to HRMS injection/processing.
- D – Dilution Data. Result was obtained from the analysis of a dilution. The number that follows the “D” indicates the dilution factor.
- DE – Indicates a dilution performed with the addition of ES (Extraction Standard) solution.
- DUP – Designation for a duplicate sample.
- MS – Designation for a matrix spike.
- MSD – Designation for a matrix spike duplicate.
- R – Indicates a re-extraction of the sample.
- RJ – Indicates a reinjection of the sample extract.



General Reporting Notes – Data Qualifiers

- S – Indicates a sample split. The number that follows the “S” indicates the split factor.
- SAT – Indicates an analyte saturated the detector.

PFAS Compound Acronym List		
Acronym	CAS #	Compound Name
Target Analytes		
* Analyte is not accredited		
PFBA	375-22-4	Perfluorobutanoic Acid
PFPeA	2706-90-3	Perfluoropentanoic Acid
PFHxA	307-24-4	Perfluorohexanoic Acid
PFHpA	375-85-9	Perfluoroheptanoic Acid
PFOA	335-67-1	Perfluorooctanoic Acid
PFNA	375-95-1	Perfluorononanoic Acid
PFDA	335-76-2	Perfluorodecanoic acid
PFUnA (PFUnDA)	2058-94-8	Perfluoroundecanoic acid
PFDoA (PFDoDA)	307-55-1	Perfluorododecanoic acid
PFTriA (PFTriA)	72629-94-8	Perfluorotridecanoic acid
PFTeDA (PFTA)	376-06-7	Perfluorotetradecanoic acid
PFBS	375-73-5	Perfluorobutane sulfonic acid
PFPeS	2706-91-4	Perfluoropentane sulfonic acid
PFHxS	355-46-4	Perfluorohexane sulfonic acid
PFHpS	375-92-8	Perfluoroheptane sulfonic acid
PFOS	1763-23-1	Perfluorooctane sulfonic acid
PFNS	68259-12-1	Perfluorononane sulfonic acid
PFDS	335-77-3	Perfluorodecane sulfonic acid
4:2 FTS	757124-72-4	4:2 fluorotelomer sulfonic acid
6:2 FTS	27619-97-2	6:2 fluorotelomer sulfonic acid
8:2 FTS	39108-34-4	8:2 fluorotelomer sulfonic acid
PFOSA (FOSA)	754-91-6	Perfluorooctane sulfonamide
N-MeFOSAA	2355-31-9	N-methyl perfluorooctane sulfonamido acetic acid
N-EtFOSAA	2991-50-6	N-ethyl perfluorooctane sulfonamido acetic acid
HFPO-DA	13252-13-6	2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy)-propanoic acid (Gen-X)
11CI-PF3OUdS	763051-92-9	11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid
9CI-PF3ONS	756426-58-1	9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid
ADONA	919005-14-4	4,8-dioxa-3H-perfluorononanoic acid
PFEESA	113507-82-7	Perfluoro(2-ethoxyethane)sulphonic acid
PFMOBA (PFMBA)	863090-89-5	Perfluoro-4-methoxybutanic acid
NFDHA	151772-58-6	Nonafluoro-3,6-dioxaheptanoic acid
PFMOPra (PFMPA)	377-73-1	Perfluoro-3-methoxypropanoic acid
* PFMOAA	674-13-5	Perfluoro-2-methoxyacetic acid
* PFO2HxA	39492-88-1	Perfluoro (3,5-dioxaheptanoic) acid
* PFO3OA	39492-89-2	Perfluoro (3,5,7-trioxaoctanoic) acid
* PFO4DA	39492-90-5	Perfluoro (3,5,7,9-tetraoxadecanoic) acid
* PFO5DA	39492-91-6	Perfluoro(3,5,7,9,11-pentaoxadodecanoic) acid
* Nafion Byproduct 1	29311-67-9	Nafion Byproduct 1
* Nafion Byproduct 2	749836-20-2	Nafion Byproduct 2
* PEPA	267239-61-2	Perfluoro-2-ethoxypropanoic acid
* PMPA	13140-29-9	Perfluoro-2-methoxypropanoic acid
* 10:2 FTS	120226-60-0	Fluorotelomer sulfonate 10:2
* N-EtFOSA	4151-50-2	N-ethylperfluoro-1-octanesulfonamide
* N-EtFOSE	1691-99-2	2-(N-methylperfluoro-1-octanesulfonamido)-ethanol
* N-MeFOSA	31506-32-8	N-methylperfluoro-1-octanesulfonamide
* N-MeFOSE	24448-09-7	2-(N-methylperfluoro-1-octanesulfonamido)-ethanol
* PFECA-G	801212-59-9	4-(Heptafluoroisopropoxy)hexafluorobutanoic acid
* PFHxDA	67905-19-5	Perfluorohexadecanoic acid
R-PSDA (Nafion Byproduct 4)	2416366-18-0	Perfluoro-4-(2-sulfoethoxy)pentanoic acid

PFAS Compound Acronym List		
Acronym	CAS #	Compound Name
Target Analytes		
* Analyte is not accredited		
* Hydrolyzed PSDA (Nafion Byproduct 5)	2416366-19-1	2-fluoro-2-[1,1,2,3,3,3-hexafluoro-2-(1,1,2,2-tetrafluoro-2-sulfoethoxy)propoxy]-acetic acid
* R-PSDCA (Nafion Byproduct 6)	2416366-21-5	1,1,2,2-tetrafluoro-2-[1,2,2,3,3-pentafluoro-1-(trifluoromethyl)propoxy] ethanesulfonic acid
* EVE Acid	69087-46-3	2,2,3,3-tetrafluoro-3-({1,1,1,2,3,3-hexafluoro-3-[(1,2,2-trifluoroethenyl)oxy]propan-2-yl}oxy)propionic acid
* FBSA	30334-69-1	Perfluorobutylsulfonamide
* Hydro-EVE Acid	773804-62-9	2,2,3,3-Tetrafluoro-3-({1,1,1,2,3,3-hexafluoro-3-(1,2,2,2-tetrafluoroethoxy)propan-2-yl}oxy)propanoic acid
* R-EVE Acid	2416366-22-6	4-(2-carboxy-1,1,2,2-tetrafluoroethoxy)-2,2,3,3,4,5,5,5-octafluoro-pentanoic acid
* NVHOS	1132933-86-8	Perfluoroethoxysulfonic acid
* PFDoS	79780-39-5	Perfluorododecane sulfonic acid
* PFODA	16517-11-6	Perfluorooctadecanoic acid
* 3:3 FTCA	356-02-5	2H,2H,3H,3H-Perfluorohexanoic acid
* 5:3 FTCA	914637-49-3	2H,2H,3H,3H-Perfluorooctanoic acid
* 7:3 FTCA	812-70-4	2H,2H,3H,3H-Perfluorodecanoic acid
* N-AP-FHxSA	50598-28-2	N-(3-(Dimethylamino)propyl)tridecafluoro-1-hexanesulfonamide
* N-CMAmP-6:2 FOSA	34455-29-3	N-(Carboxymethyl)-N,N-dimethyl-3-(((3,3,4,4,5,5,6,6,7,7,8,8,8-tridecafluorooctyl)sulfonyl)amino)1-propanaminium

Sample Custody

**This Is The Last Page
Of This Report.**