

County of Brunswick


3954 Clearwell Dr NE
Leland, NC 28451

Northwest Water Plant

Leland, NC
Samples Received: 11/12/20

Analytical Report 1120-729

Isotope Dilution Method PFAS



Enthalpy Analytical, LLC – Ultratrace

Lindsay Boone
O: (910) 212-5855 / F: 910-212-5866
lboone@enthalpy.com / www.enthalpy.com
2714 Exchange Drive, Wilmington, NC 28405

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains _____ pages.

....."Report Issued Date: _____"



Summary of Results

Enthalpy Analytical

Job No.: 1120-729-1 PFAS by Isotope Dilution (non-potable water)

County of Brunswick Site: Northwest Water Plant

Summary

	Compound	CAS	11-12-20-S01 ng/L	11-12-20-E01 ng/L
Acids	PFBA	375-22-4	ND U	ND U
	PFPeA	2706-90-3	ND U	ND U
	PFHxA	307-24-4	6.10	6.06
	PFHpA	375-85-9	2.97	3.19
	PFOA	335-67-1	5.20	5.48
	PFNA	375-95-1	0.729	0.843
	PFDA	335-76-2	0.372	0.336
	PFUnDA	2058-94-8	0.0879 J	0.0630 J
	PFDoDA	307-55-1	0.0635 J	ND U
	PFTTrDA	72629-94-8	ND U	ND U
	PFTeDA	376-06-7	ND U	ND U
Sulfonates	PFBS	375-73-5	ND U	ND U
	PFPeS	2706-91-4	0.646	0.695
	PFHxS	355-46-4	3.25	3.31
	PFHpS	375-92-8	0.323	0.193 J
	PFOS	1763-23-1	8.52	8.01
	PFNS	68259-12-1	ND U	ND U
	PFDS	335-77-3	ND U	ND U
	4:2 FTS	757124-72-4	ND U	ND U
	6:2 FTS	27619-97-2	0.425	0.627
	8:2 FTS	39108-34-4	ND U	ND U
	other	PFOSA	754-91-6	ND U
N-MeFOSAA		2355-31-9	0.0213 LB	0.0188 LB
N-EtFOSAA		2991-50-6	ND U	ND U
HFPO-DA		13252-13-6	6.78	8.86
PFMOAA		674-13-5	55.0	40.3
PFMOPrA		377-73-1	ND U	ND U
PFO2HxA		39492-88-1	2.06	3.83
PFO3OA		39492-89-2	7.15	7.63
PFO4DA		39492-90-5	4.70	ND U
Nafion Byproduct 1		29311-67-9	0.201 L	0.321
ADONA		919005-14-4	ND U	ND U
9Cl-PF3ONS		756426-58-1	ND U	ND U
11Cl-PF3OUdS		763051-92-9	ND U	ND U
10:2 FTS		120226-60-0	ND U	ND U
FBSA		30334-69-1	0.790	0.902
N-EtFOSA		4151-50-2	ND U	ND U
N-EtFOSE		1691-99-2	ND U	ND U
N-MeFOSA		31506-32-8	ND U	ND U
N-MeFOSE		24448-09-7	ND U	ND U
Nafion Byproduct 2		749836-20-2	0.357 L	0.511 L
NFDHA		151772-58-6	ND U	ND U
PEPA			ND U	ND U
PFECA-G		801212-59-9	ND U	ND U
PFEEESA		113507-82-7	ND U	ND U
PFHxDA		67905-19-5	ND U	ND U
PFMOBA		863090-89-5	ND U	ND U
PFO5DA		39492-91-6	ND U	ND U
PMPA		13140-29-9	ND U	ND U

Detailed Results

Enthalpy Analytical

Job No.: 1120-729-1 PFAS by Isotope Dilution (non-potable water)
 County of Brunswick Site: Northwest Water Plant

Enthalpy ID 1120-729-001-1 Prep Batch EU11294 Sample Vol (mL) 286.48
 Sample Name 11-12-20-S01 Prep Date 2020-11-13 Extract Vol (mL) 0.4
 Matrix Aqueous Analysis Date 2020-11-14 Dilution Factor 1
 Sampling Date 11/12/2020

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery	Flags	
Acids	PFBA	375-22-4	ND	ND	ND	0.137	0.257		U	
	PFPeA	2706-90-3	ND	ND	ND	0.0783	0.257		U	
	PFHxA	307-24-4	4368.91	6.10	6.10	0.138	0.257			
	PFHpA	375-85-9	2125.62	2.97	2.97	0.0606	0.257			
	PFOA	335-67-1	3720.98	5.20	5.20	0.0693	0.257			
	PFNA	375-95-1	521.91	0.729	0.729	0.0444	0.257			
	PFDA	335-76-2	266.14	0.372	0.372	0.109	0.257			
	PFUnDA	2058-94-8	62.97	0.0879	0.0879	0.0420	0.257		J	
	PFDODA	307-55-1	45.51	0.0635	0.0635	0.0415	0.257		J	
	PFTriDA	72629-94-8	ND	ND	ND	0.0650	0.257		U	
	PFTeDA	376-06-7	ND	ND	ND	0.0724	0.257		U	
	Sulfonates	PFBS	375-73-5	ND	ND	ND	0.0724	0.257		U
		PFPeS	2706-91-4	462.66	0.646	0.646	0.0864	0.257		
PFHxS		355-46-4	2324.15	3.25	3.25	0.0722	0.257			
PFHpS		375-92-8	231.24	0.323	0.323	0.0680	0.257			
PFOS		1763-23-1	6098.48	8.52	8.52	0.0411	0.257			
PFNS		68259-12-1	ND	ND	ND	0.0571	0.257		U	
PFDS		335-77-3	ND	ND	ND	0.118	0.257		U	
4:2 FTS		757124-72-4	ND	ND	ND	0.0564	0.257		U	
6:2 FTS		27619-97-2	304.38	0.425	0.425	0.0631	0.257			
8:2 FTS		39108-34-4	ND	ND	ND	0.0497	0.257		U	
other	PFOSA	754-91-6	ND	ND	ND	0.319	0.320		U	
	N-MeFOSAA	2355-31-9	15.23	0.0213	0.0213	0.0475	0.257		LB	
	N-EiFOSAA	2991-50-6	ND	ND	ND	0.0568	0.257		U	
	HFPO-DA	13252-13-6	4853.89	6.78	6.78	0.0830	0.257			
	PFMOAA	674-13-5	39410.50	55.0	55.0	1.29	1.29			
	PFMOPrA	377-73-1	ND	ND	ND	0.209	0.257		U	
	PFO2HxA	39492-88-1	1478.43	2.06	2.06	1.29	1.29			
	PFO3OA	39492-89-2	5117.91	7.15	7.15	1.29	1.29			
	PFO4DA	39492-90-5	3367.49	4.70	4.70	1.29	1.29			
	Nafion Byproduct 1	29311-67-9	143.69	0.201	0.201	0.209	0.257		L	
	ADONA	919005-14-4	ND	ND	ND	0.105	0.257		U	
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.105	0.257		U	
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.105	0.257		U	
	10:2 FTS	120226-60-0	ND	ND	ND	0.209	0.257		U	
	FBSA	30334-69-1	565.88	0.790	0.790	0.209	0.257			
	N-EiFOSA	4151-50-2	ND	ND	ND	0.209	0.257		U	
	N-EiFOSE	1691-99-2	ND	ND	ND	6.28	6.28		U	
	N-MeFOSA	31506-32-8	ND	ND	ND	0.209	0.257		U	
	N-MeFOSE	24448-09-7	ND	ND	ND	6.28	6.28		U	
	Nafion Byproduct 2	749836-20-2	255.96	0.357	0.357	1.29	1.29		L	
	NFDHA	151772-58-6	ND	ND	ND	0.209	0.257		U	
	PEPA		ND	ND	ND	1.29	1.29		U	
	PFECA-G	801212-59-9	ND	ND	ND	1.29	1.29		U	
	PFEESA	113507-82-7	ND	ND	ND	0.209	0.257		U	
	PFHxDA	67905-19-5	ND	ND	ND	1.29	1.29		U	
	PFMOBA	863090-89-5	ND	ND	ND	1.29	1.29		U	
	PFO5DA	39492-91-6	ND	ND	ND	2.62	2.62		U	
	PMPA	13140-29-9	ND	ND	ND	1.29	1.29		U	
ES	MPFBA		4684.21	6.54				16.8%	Q	
	M5PFPeA		15074.35	21.0				49.9%		
	M3PFBS		29430.61	41.1				100.1%		
	M2-4:2 FTS		69707.55	97.3				264.1%	Q	
	M5PFHxA		4033.75	5.63				86.3%		
	M3HFPO-DA		4714.34	6.58				106.6%		
	M4PFHpA		4653.46	6.50				99.8%		
	M3PFHxS		5123.92	7.15				112.3%		
	M2-6:2 FTS		49892.63	69.7				180.3%	Q	
	M8PFOA		4501.41	6.29				98.0%		
	M9PFNA		4407.89	6.15				90.9%		
	M8PFOS		4400.33	6.14				92.8%		
	M2-8:2 FTS		3948.95	5.51				97.5%		
	M8FOSA-I		2761.79	3.86				63.4%		
	M6PFDA		4477.64	6.25				91.3%		
	d3-N-MeFOSAA		4054.05	5.66				95.5%		
	d5-N-EiFOSAA		3842.08	5.36				90.9%		
	M7PFUdA		3992.31	5.57				81.0%		
	MPFDoA		3157.06	4.41				71.5%		
	M2PFTeDA		1652.74	2.31				35.1%		

Enthalpy Analytical

Job No.: 1120-729-1 PFAS by Isotope Dilution (non-potable water)
 County of Brunswick Site: Northwest Water Plant

Enthalpy ID 1120-729-002-1 Prep Batch EU11294 Sample Vol (mL) 287.19
 Sample Name 11-12-20-E01 Prep Date 2020-11-13 Extract Vol (mL) 0.4
 Matrix Aqueous Analysis Date 2020-11-14 Dilution Factor 1
 Sampling Date 11/12/2020

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery	Flags
Acids	PFBA	375-22-4	ND	ND	ND	0.137	0.256		U
	PFPeA	2706-90-3	ND	ND	ND	0.0781	0.256		U
	PFHxA	307-24-4	4348.82	6.06	6.06	0.137	0.256		
	PFHpA	375-85-9	2293.53	3.19	3.19	0.0605	0.256		
	PFOA	335-67-1	3934.48	5.48	5.48	0.0692	0.256		
	PFNA	375-95-1	605.12	0.843	0.843	0.0443	0.256		
	PFDA	335-76-2	241.13	0.336	0.336	0.109	0.256		
	PFUnDA	2058-94-8	45.25	0.0630	0.0630	0.0419	0.256		J
	PFDaDA	307-55-1	ND	ND	ND	0.0413	0.256		U
	PFTriDA	72629-94-8	ND	ND	ND	0.0649	0.256		U
	PFTeDA	376-06-7	ND	ND	ND	0.0723	0.256		U
	Sulfonates	PFBS	375-73-5	ND	ND	ND	0.0723	0.256	
PFPeS		2706-91-4	499.22	0.695	0.695	0.0862	0.256		
PFHxS		355-46-4	2376.82	3.31	3.31	0.0720	0.256		
PFHpS		375-92-8	138.47	0.193	0.193	0.0678	0.256		J
PFOS		1763-23-1	5752.18	8.01	8.01	0.0410	0.256		
PFNS		68259-12-1	ND	ND	ND	0.0569	0.256		U
PFDS		335-77-3	ND	ND	ND	0.118	0.256		U
4:2 FTS		757124-72-4	ND	ND	ND	0.0562	0.256		U
6:2 FTS		27619-97-2	450.52	0.627	0.627	0.0629	0.256		
8:2 FTS		39108-34-4	ND	ND	ND	0.0495	0.256		U
other	PFOSA	754-91-6	41.79	0.0582	0.0582	0.318	0.319		L
	N-MeFOSAA	2355-31-9	13.52	0.0188	0.0188	0.0474	0.256		LB
	N-EiFOSAA	2991-50-6	ND	ND	ND	0.0567	0.256		U
	HFPO-DA	13252-13-6	6364.14	8.86	8.86	0.0828	0.256		
	PFMOAA	674-13-5	28944.10	40.3	40.3	1.29	1.29		
	PFMOPrA	377-73-1	ND	ND	ND	0.209	0.256		U
	PFO2HxA	39492-88-1	2750.52	3.83	3.83	1.29	1.29		
	PFO3OA	39492-89-2	5481.48	7.63	7.63	1.29	1.29		
	PFO4DA	39492-90-5	ND	ND	ND	1.29	1.29		U
	Nafion Byproduct 1	29311-67-9	230.73	0.321	0.321	0.209	0.256		
	ADONA	919005-14-4	ND	ND	ND	0.104	0.256		U
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.104	0.256		U
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.104	0.256		U
	10:2 FTS	120226-60-0	ND	ND	ND	0.209	0.256		U
	FBSA	30334-69-1	647.51	0.902	0.902	0.209	0.256		
	N-EiFOSA	4151-50-2	ND	ND	ND	0.209	0.256		U
	N-EiFOSE	1691-99-2	ND	ND	ND	6.27	6.27		U
	N-MeFOSA	31506-32-8	ND	ND	ND	0.209	0.256		U
	N-MeFOSE	24448-09-7	ND	ND	ND	6.27	6.27		U
	Nafion Byproduct 2	749836-20-2	367.03	0.511	0.511	1.29	1.29		L
	NFDHA	151772-58-6	ND	ND	ND	0.209	0.256		U
	PEPA		ND	ND	ND	1.29	1.29		U
	PFECA-G	801212-59-9	ND	ND	ND	1.29	1.29		U
	PFEESA	113507-82-7	ND	ND	ND	0.209	0.256		U
	PFHxDA	67905-19-5	ND	ND	ND	1.29	1.29		U
	PFMOBA	863090-89-5	ND	ND	ND	1.29	1.29		U
	PFO5DA	39492-91-6	ND	ND	ND	2.62	2.62		U
	PMPA	13140-29-9	ND	ND	ND	1.29	1.29		U
ES	MPFBA		4687.10	6.53				16.1%	Q
	M5PFPeA		12360.07	17.2				39.2%	
	M3PFBS		20590.94	28.7				67.1%	
	M2-4:2 FTS		47518.75	66.2				172.5%	Q
	M5PFHxA		4449.31	6.20				60.5%	
	M3HFPO-DA		4520.67	6.30				65.0%	
	M4PFHpA		4891.07	6.81				66.7%	
	M3PFHxS		5015.22	6.99				70.6%	
	M2-6:2 FTS		27513.52	38.3				95.2%	
	M8PFOA		4696.80	6.54				65.1%	
	M9PFNA		4476.98	6.24				58.7%	
	M8PFOS		4497.32	6.26				61.0%	
	M2-8:2 FTS		3534.51	4.92				56.1%	
	M8FOSA-I		3497.30	4.87				51.6%	
	M6PFDA		4168.87	5.81				56.7%	
	d3-N-MeFOSAA		3783.08	5.27				57.3%	
	d5-N-EiFOSAA		3632.87	5.06				55.3%	
	M7PFUdA		3755.68	5.23				50.8%	
	MPFDaA		2996.75	4.17				45.3%	
	M2PFTeDA		2763.37	3.85				39.2%	

QC Data

Enthalpy Analytical

Job No.: 1120-729-1 PFAS by Isotope Dilution (non-potable water)

County of Brunswick Site: Northwest Water Plant

Enthalpy ID	MB-11294-PFAS	Prep Batch	EU11294	Sample Vol (mL)	250
Sample Name	MB-11294-PFAS	Prep Date	2020-11-13	Extract Vol (mL)	0.4
Matrix	Aqueous	Analysis Date	2020-11-14	Dilution Factor	1
Sampling Date					

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery	Flags	
Acids	PFBA	375-22-4	ND	ND	ND	0.157	0.294		U	
	PFPeA	2706-90-3	ND	ND	ND	0.0898	0.294		U	
	PFHxA	307-24-4	9.17	0.0147	0.0147	0.158	0.294		L	
	PFFHpA	375-85-9	ND	ND	ND	0.0695	0.294		U	
	PFOA	335-67-1	36.76	0.0588	0.0588	0.0795	0.294		L	
	PFNA	375-95-1	ND	ND	ND	0.0509	0.294		U	
	PFDA	335-76-2	ND	ND	ND	0.125	0.294		U	
	PFUnDA	2058-94-8	ND	ND	ND	0.0481	0.294		U	
	PFDODA	307-55-1	ND	ND	ND	0.0475	0.294		U	
	PFTriDA	72629-94-8	ND	ND	ND	0.0745	0.294		U	
	PFTeDA	376-06-7	ND	ND	ND	0.0830	0.294		U	
	Sulfonates	PFBS	375-73-5	ND	ND	ND	0.0830	0.294		U
		PFPeS	2706-91-4	ND	ND	ND	0.0990	0.294		U
PFFHxS		355-46-4	ND	ND	ND	0.0827	0.294		U	
PFFHpS		375-92-8	ND	ND	ND	0.0779	0.294		U	
PFOS		1763-23-1	ND	ND	ND	0.0471	0.294		U	
PFNS		68259-12-1	ND	ND	ND	0.0654	0.294		U	
PFDS		335-77-3	ND	ND	ND	0.135	0.294		U	
4:2 FTS		757124-72-4	ND	ND	ND	0.0646	0.294		U	
6:2 FTS		27619-97-2	ND	ND	ND	0.0723	0.294		U	
8:2 FTS		39108-34-4	ND	ND	ND	0.0569	0.294		U	
other	PFOSA	754-91-6	ND	ND	ND	0.365	0.366		U	
	N-MeFOSAA	2355-31-9	130.11	0.208	0.208	0.0544	0.294		J	
	N-EiFOSAA	2991-50-6	ND	ND	ND	0.0651	0.294		U	
	HFPO-DA	13252-13-6	ND	ND	ND	0.0951	0.294		U	
	PFMOAA	674-13-5	ND	ND	ND	1.48	1.48		U	
	PFMOPrA	377-73-1	ND	ND	ND	0.240	0.294		U	
	PFO2HxA	39492-88-1	ND	ND	ND	1.48	1.48		U	
	PFO3OA	39492-89-2	ND	ND	ND	1.48	1.48		U	
	PFO4DA	39492-90-5	ND	ND	ND	1.48	1.48		U	
	Nafion Byproduct 1	29311-67-9	ND	ND	ND	0.240	0.294		U	
	ADONA	919005-14-4	ND	ND	ND	0.120	0.294		U	
	9Cl-PF3ONS	756426-58-1	ND	ND	ND	0.120	0.294		U	
	11Cl-PF3OUdS	763051-92-9	ND	ND	ND	0.120	0.294		U	
	10:2 FTS	120226-60-0	ND	ND	ND	0.240	0.294		U	
	FBSA	30334-69-1	ND	ND	ND	0.240	0.294		U	
	N-EiFOSA	4151-50-2	ND	ND	ND	0.240	0.294		U	
	N-EiFOSE	1691-99-2	ND	ND	ND	7.20	7.20		U	
	N-MeFOSA	31506-32-8	ND	ND	ND	0.240	0.294		U	
	N-MeFOSE	24448-09-7	ND	ND	ND	7.20	7.20		U	
	Nafion Byproduct 2	749836-20-2	ND	ND	ND	1.48	1.48		U	
	NFDHA	151772-58-6	ND	ND	ND	0.240	0.294		U	
	PEPA		ND	ND	ND	1.48	1.48		U	
	PFECA-G	801212-59-9	ND	ND	ND	1.48	1.48		U	
	PFEESA	113507-82-7	ND	ND	ND	0.240	0.294		U	
	PFFHxDA	67905-19-5	ND	ND	ND	1.48	1.48		U	
	PFMOBA	863090-89-5	ND	ND	ND	1.48	1.48		U	
	PFO5DA	39492-91-6	ND	ND	ND	3.01	3.01		U	
	PMPA	13140-29-9	ND	ND	ND	1.48	1.48		U	
	ES	MPFBA		5575.23	8.92				76.7%	
		M5PFPeA		5855.34	9.37				74.2%	
M3PFBS			6034.60	9.66				78.7%		
M2-4:2 FTS			5422.70	8.68				78.7%		
M5PFHxA			5506.99	8.81				77.8%		
M3HFPO-DA			6448.88	10.3				96.4%		
M4PFHpA			5526.22	8.84				78.3%		
M3PFHxS			5934.29	9.49				84.5%		
M2-6:2 FTS			6171.23	9.87				85.4%		
M8PFOA			5274.16	8.44				75.9%		
M9PFNA			5309.07	8.49				72.3%		
M8PFOS			5184.37	8.29				71.0%		
M2-8:2 FTS			4480.39	7.17				71.9%		
M8FOSA-I			3639.34	5.82				54.2%		
M6PFDA			5392.61	8.63				72.2%		
d3-N-MeFOSAA			4854.11	7.77				74.3%		
d5-N-EiFOSAA			4367.31	6.99				67.1%		
M7PFUdA			4818.94	7.71				64.1%		
MPFDaA			3798.06	6.08				56.5%		
M2PFTeDA			3067.10	4.91				42.8%		

Enthalpy Analytical

Job No.: 1120-729-1 PFAS by Isotope Dilution (non-potable water)

County of Brunswick Site: Northwest Water Plant

Enthalpy ID	OPR-11294-PFAS	Prep Batch	EU11294	Sample Vol (mL)	250
Sample Name	OPR-11294-PFAS	Prep Date	2020-11-13	Extract Vol (mL)	0.4
Matrix	Aqueous	Analysis Date	2020-11-14	Dilution Factor	1
Sampling Date					

	Compound	CAS	Extract Concentration ng/L	Sample Concentration ng/L	Formatted Result ng/L	LOD ng/L	LOQ ng/L	Recovery	Flags
Acids	PFBA	375-22-4	11077.33	17.7	17.7	0.157	0.294	88.6%	
	PFPeA	2706-90-3	11117.20	17.8	17.8	0.0898	0.294	88.9%	
	PFHxA	307-24-4	11178.91	17.9	17.9	0.158	0.294	89.4%	
	PFHpA	375-85-9	10436.34	16.7	16.7	0.0695	0.294	83.5%	
	PFOA	335-67-1	10629.87	17.0	17.0	0.0795	0.294	85.0%	
	PFNA	375-95-1	10934.73	17.5	17.5	0.0509	0.294	87.5%	
	PFDA	335-76-2	11279.30	18.0	18.0	0.125	0.294	90.2%	
	PFUnDA	2058-94-8	10822.25	17.3	17.3	0.0481	0.294	86.6%	
	PFDoDA	307-55-1	10866.14	17.4	17.4	0.0475	0.294	86.9%	
	PFTTrDA	72629-94-8	13689.84	21.9	21.9	0.0745	0.294	109.5%	
	PFTeDA	376-06-7	12104.89	19.4	19.4	0.0830	0.294	96.8%	
Sulfonates	PFBS	375-73-5	8961.36	14.3	14.3	0.0830	0.294	80.8%	
	PFPeS	2706-91-4	9466.49	15.1	15.1	0.0990	0.294	80.5%	
	PFHxS	355-46-4	9531.66	15.3	15.3	0.0827	0.294	83.4%	
	PFHpS	375-92-8	9359.26	15.0	15.0	0.0779	0.294	78.6%	
	PFOS	1763-23-1	8739.48	14.0	14.0	0.0471	0.294	75.3%	
	PFNS	68259-12-1	9180.92	14.7	14.7	0.0654	0.294	76.3%	
	PFDS	335-77-3	11130.08	17.8	17.8	0.135	0.294	92.3%	
	4:2 FTS	757124-72-4	10944.73	17.5	17.5	0.0646	0.294	93.4%	
	6:2 FTS	27619-97-2	10309.45	16.5	16.5	0.0723	0.294	86.7%	
8:2 FTS	39108-34-4	10959.54	17.5	17.5	0.0569	0.294	91.3%		
Other	PFOSA	754-91-6	11252.12	18.0	18.0	0.365	0.366	90.0%	
	N-MeFOSAA	2355-31-9	11383.94	18.2	18.2	0.0544	0.294	91.1%	
	N-EtFOSAA	2991-50-6	10648.94	17.0	17.0	0.0651	0.294	85.2%	
	HFPO-DA	13252-13-6	9405.36	15.0	15.0	0.0951	0.294	75.2%	
ES	MPFBA		5208.11	8.33				85.0%	
	M5PFPeA		5508.53	8.81				82.8%	
	M3PFBS		5622.69	9.00				86.9%	
	M2-4:2 FTS		5477.19	8.76				94.3%	
	M5PFHxA		5474.80	8.76				84.3%	
	M3HFPO-DA		7373.46	11.8				120.0%	
	M4PFHpA		5387.50	8.62				83.1%	
	M3PFHxS		5223.98	8.36				90.2%	
	M2-6:2 FTS		6414.04	10.3				105.3%	
	M8PFOA		5445.40	8.71				85.3%	
	M9PFNA		5582.98	8.93				82.8%	
	M8PFOS		5297.55	8.48				88.1%	
	M2-8:2 FTS		4435.00	7.10				86.3%	
	M8FOSA-I		4135.32	6.62				74.8%	
	M6PFDA		5276.14	8.44				80.3%	
	d3-N-MeFOSAA		4319.07	6.91				80.2%	
	d5-N-EtFOSAA		4460.60	7.14				83.2%	
	M7PFUDa		5115.44	8.18				77.5%	
MPFDoA		4319.05	6.91				73.1%		
M2PFTeDA		3440.83	5.51				54.6%		

Narrative Summary



Enthalpy Analytical Narrative Summary

Company	County of Brunswick
Job No.	1120-729 PFAS by Isotope Dilution (non-potable water)
Client ID.	N/A Site: Northwest Water Plant

1. Custody

Anthony Stokes received the samples on 11/12/20 at 7.0°C after being relinquished by County of Brunswick. The samples were received in good condition.

Prior to, during, and after analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, LLC.

Table 1 - Sample Inventory

EU Lab Sample ID	Client Sample ID	Matrix
1120-729-1120729002-1	11-12-20-E01	aqueous
1120-729-1120729001-1	11-12-20-S01	aqueous

2. Methods and analytes

A list of analytes of interest and corresponding methods of analysis is shown in Table 3. Abbreviations are defined in the listed Appendices.

Table 3 - Methods and Analytes

EU Method	Analytes	Cleanup Method
EU-047	PFAS Full List	ENVI-Carb

3. Analysis

The samples were analyzed using Waters Acquity UPLC equipped with Xevo TQ MS (LC/MS/MS "Kili").

For aqueous samples, the sample volume was measured gravimetrically by the laboratory, and spiked with Extraction Standard (ES). The sample was then mixed well and centrifuged.

Cleanup procedures were performed on the supernatant and then extracted via SPE. Each final sample extract was transferred to an autosampler vial and spiked with 80µL of Injection Standard (IS), prior to analysis.



Enthalpy Analytical Narrative Summary

Company	County of Brunswick
Job No.	1120-729 PFAS by Isotope Dilution (non-potable water)
Client ID.	N/A Site: Northwest Water Plant

4. Calibration

In the initial calibration, the analytes exhibited R^2 of ≥ 0.99 . The calibration standard analytes, continuing calibration (concal) and Initial Calibration Verification (ICV) met the 30% criterion for native analytes.

5. QC Notes

QC sample analyses passed all method criteria.

An analyte(s) was detected in the method blank (MB) below the Reporting Limit (RL) with values more than 1/10 the sample amount. Any analyte(s) detected in the sample(s) associated with the analyte(s) found in the MB are notated with a B qualifier.

The samples were extracted within the 28-day from collection holding time and analyzed within the 28-day from extraction to analysis holding time required by the method.

6. Reporting Notes

Some labeled standards in the samples fell outside the limits for ES recoveries, notated by the Q qualifier. The target analytes are quantified based on their ratio to the labeled standards, therefore, undergo the same losses as the labeled standards. As a result, low or high recoveries do not cause any change to ratios or contribute any additional error in the measurement of the target analytes. Therefore, the data are considered acceptable.

The results presented in this report are representative of the samples as provided to the laboratory.

These analyses met the requirements of the TNI Standard. Any deviations from the requirements of the reference method or TNI Standard have been stated above.

Enthalpy Analytical, LLC in Wilmington NC is accredited by the Louisiana Department of Environmental Quality to the 2009 TNI Standard under certificate number 05075.





General Reporting Notes – Data Qualifiers

The following are general reporting notes that are applicable to all Enthalpy Analytical, LLC - Wilmington, NC data reports, unless specifically noted otherwise.

General Data Qualifiers

- B – The analyte was found in the method blank, at a concentration that was at least 10% of the concentration in the sample.
- Cxx – Two or more congeners co-elute. In EDDs, C denotes the lowest IUPAC congener in a co-elution group and additional co-eluters for the group ('xx') are shown with the number of the lowest IUPAC co-eluter.
- E – The reported concentration exceeds the calibration range (upper point of the calibration curve). For HRMS data, this condition does not imply additional measurement uncertainty. For LC-MS/MS data, these values should be considered as having measurement uncertainty higher than values within the calibration range.
- EDL – Estimated Detection Level. Specific to Dioxin/Furan tests and equivalent to MDL
- EMPC – Estimated Maximum Possible Concentration Specific to Dioxin/Furan tests to indicate the signal/noise ratio was not sufficient for peak identification (the determined ion-abundance ratio was outside the allowed theoretical range), or where there was a co-eluting interference. Indicates that a peak was identified but did not meet the method specified ion-abundance ratio.
- IR – The ion ratio between the primary and secondary ions was observed to be outside the method criteria therefore the actual analyte concentration cannot be accurately determined as defined by DoD QSM Table B-15.
- J – The analyte has a concentration below the minimum calibration level (LOQ value) but greater than the LOD. These values should be considered as having measurement uncertainty higher than values within the calibration range
- L - Indicates that an analyte has a concentration below the Minimum Detection Limit (MDL). The reported concentration is not recommended for regulatory use as the analyte signal may have a signal-to-noise ratio less than the criteria deemed necessary to be considered a detected analyte.
- LOD – Limit of Detection: For reports conforming to the DOD ELAP QSM, this is the QSM-defined LOD. For reports conforming to TNI requirements (but not DOD ELAP QSM requirements), this value is the minimum detection limit (MDL). The LOD is adjusted for sample weight or volume.
- LOQ – Limit of Quantiation: For reports conforming to the DOD ELAP QSM, this is the QSM-defined LOQ. For reports conforming to TNI requirements (but not DOD ELAP QSM requirements), this value is the reporting limit (RL). The LOD is adjusted for sample weight or volume.
- <LOD() – Analyte was not found at a concentration high enough to be reported as detected. It is reported as less than the LOD, and the LOD is given in the parentheses.



General Reporting Notes – Data Qualifiers

- ND – Indicates a non-detect.
- NR – Indicates a value that is not reportable due to issues observed in sample preparation or analysis.
- PR – The associated congener(s) is(are) poorly resolved.
- QI – Indicates the presence of a quantitative interference.
- RL – Reporting Limit. Lowest reportable value. The level is higher than the MDL.
- SI – Denotes “Single Ion Mode” and is utilized for PCBs where the secondary ion trace has a significantly elevated noise level due to background PFK. Responses for such peaks are calculated using an EMPC approach based solely on the primary ion area(s) and may be considered estimates.
- U – The analyte was not detected.
- V – The labeled standard recovery is not within method control limits.
- X – Results from re-injection/repeat/second-column analysis.

Lab Identifiers/ Data Attributes

- AR – Indicates use of the archived portion of the sample extract.
- CU – Indicates a sample that required additional clean-up prior to HRMS injection/processing.
- D – Dilution Data. Result was obtained from the analysis of a dilution. The number that follows the “D” indicates the dilution factor.
- DE – Indicates a dilution performed with the addition of ES (Extraction Standard) solution.
- DUP – Designation for a duplicate sample.
- MS – Designation for a matrix spike.
- MSD – Designation for a matrix spike duplicate.
- RJ – Indicates a reinjection of the sample extract.
- S – Indicates a sample split. The number that follows the “S” indicates the split factor.
- R – Indicates a re-extraction of the sample.

PFAS Compound Acronym List

Acronym	Compound Name	CAS #
Target Analytes		
PFBA	Perfluorobutanoic Acid	375-22-4
PFPeA	Perfluoropentanoic Acid	2706-90-3
PFHxA	Perfluorohexanoic Acid	307-24-4
PFHpA	Perfluoroheptanoic Acid	375-85-9
PFOA	Perfluorooctanoic Acid	335-67-1
PFNA	Perfluorononanoic Acid	375-95-1
PFDA	Perfluorodecanoic acid	335-76-2
PFUnA (PFUnDA)	Perfluoroundecanoic acid	2058-94-8
PFDoA (PFDoDA)	Perfluorododecanoic acid	307-55-1
PFTriA (PFTriA)	Perfluorotridecanoic acid	72629-94-8
PFTeDA (PFTA)	Perfluorotetradecanoic acid	376-06-7
PFBS	Perfluorobutane sulfonic acid	375-73-5
PFPeS	Perfluoropentane sulfonic acid	2706-91-4
PFHxS	Perfluorohexane sulfonic acid	355-46-4
PFHpS	Perfluoroheptane sulfonic acid	375-92-8
PFOS	Perfluorooctane sulfonic acid	1763-23-1
PFNS	Perfluorononane sulfonic acid	68259-12-1
PFDS	Perfluorodecane sulfonic acid	757124-72-4
4:2 FTS	4:2 fluorotelomer sulfonic acid	27619-97-2
6:2 FTS	6:2 fluorotelomer sulfonic acid	39108-34-4
8:2 FTS	8:2 fluorotelomer sulfonic acid	13252-13-6
PFOSA (FOSA)	Perfluorooctane sulfonamide	754-91-6
N-MeFOSAA	N-methyl perfluorooctane sulfonamido acetic acid	2355-31-9
N-EtFOSAA	N-ethyl perfluorooctane sulfonamido acetic acid	2991-50-6
* HFPO-DA	2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy)-propanoic acid (Gen-X)	13252-13-6
* 11CI-PF3OUdS	11-chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	674-13-5
* 9CI-PF3ONS	9-chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	919005-14-4
* ADONA	4,8-dioxa-3H-perfluorononanoic acid	756426-58-1
* PFMOAA	Perfluoro-2-methoxyacetic acid	763051-92-9
* PFMOPrA	Perfluoro-3-methoxypropanoic acid	377-73-1
* PFO2HxA	Perfluoro (3,5-dioxahexanoic) acid	39492-88-1
* PFO3OA	Perfluoro (3,5,7-trioxaoctanoic) acid	39492-89-2
* PFO4DA	Perfluoro (3,5,7,9-tetraoxadecanoic) acid	39492-90-5
* PFO5DA	Perfluoro(3,5,7,9,11-pentaoxadodecanoic) acid	39492-91-6
* Nafion Byproduct 1	Nafion Byproduct 1	29311-67-9
* Nafion Byproduct 2	Nafion Byproduct 2	749836-20-2
* PFEESA	Perfluoro(2-ethoxyethane)sulphonic acid	113507-82-7
* PFMOBA	Perfluoro-4-methoxybutanic acid	863090-89-5
* PEPA	Perfluoro-2-ethoxypropanoic acid	N/A
* PMPA	Perfluoro-2-methoxypropanoic acid	13140-29-9
* 10:2 FTS	Fluorotelomer sulfonate 10:2	120226-60-0
* N-EtFOSA	N-ethylperfluoro-1-octanesulfonamide	4151-50-2
* N-EtFOSE	2-(N-methylperfluoro-1-octanesulfonamido)-ethanol	1691-99-2
* N-MeFOSA	N-methylperfluoro-1-octanesulfonamide	31506-32-8
* N-MeFOSE	2-(N-methylperfluoro-1-octanesulfonamido)-ethanol	24448-09-7
* PFECA-G	4-(Heptafluoroisopropoxy)hexafluorobutanoic acid	801212-59-9
* PFHxDA	Perfluorohexadecanoic acid	67905-19-5

Extraction Standards		
MPFBA	Perfluoro-n-[13C4]butanoic acid	
M5PFPeA	Perfluoro-n-[13C5]pentanoic acid	
M3PFBS	Sodium perfluoro-1-[2,3,4-13C3]-butanesulfonic acid	
M2-4:2 FTS	Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]-hexane sulfonic acid	
M5PFHxA	Perfluoro-n-[1,2,3,4,6-13C5]hexanoic acid	
M3HFPO-DA	2,3,3,3-Tetrafluoro-2-(1,1,2,2,3,3,3-heptafluoropropoxy)-13C3-propanoic acid	
M4PFHpA	Perfluoro-n-[1,2,3,4-13C4]heptanoic acid	
M3PFHxS	Sodium perfluoro-1-[1,2,3-13C3]-hexanesulfonic acid	
M2-6:2 FTS	Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]-octane sulfonic acid	
M8PFOA	Perfluoro-n-[13C8]octanoic acid	
M9PFNA	Perfluoro-n-[13C9]nonanoic acid	
M8PFOS	Sodium perfluoro-1-[13C8]-octanesulfonic acid	
M2-8:2 FTS	Sodium 1H,1H,2H,2H-perfluoro-1-[1,2-13C2]-decane sulfonic acid	
M8FOSA	Perfluoro-1-[13C8]octanesulfonamide	
M6PFDA	Perfluoro-n-[1,2,3,4,5,6-13C6]decanoic acid	
d3-N-MeFOSAA	N-methyl-d3-perfluoro-1-octanesulfonamide	
d5-N-EtFOSAA	N-ethyl-d5-perfluoro-1-octanesulfonamide	
M7PFUnDA (M7PFUdA)	Perfluoro-n-[1,2,3,4,5,6,7-13C7]undecanoic acid	
MPFDoA	Perfluoro-n-[1,2-13C2]dodecanoic acid	
M2PFTeDA	Perfluoro-n-[1,2-13C2]tetradecanoic acid	
Injection Standards		
M3PFBA	Perfluoro-n-[2,3,4-13C3]butanoic acid	
M2PFOA	Perfluoro-n-[1,2-13C2]octanoic acid	
MPFDA	Perfluoro-n-[1,2-13C2]decanoic acid	
MPFOS	Sodium perfluoro-1-[1,2,3,4-13C4]-octanesulfonic acid	

* Analytes are currently not accredited under TNI Standard. Accreditation pending.

Sample Custody

**This Is The Last Page
Of This Report.**